



NOTES:

1. Minimum pipe dia. to be 300mm under road pavements, minimum 225mm dia elsewhere except for house connections.
2. Reinforced concrete or FRC pipes or other approved are to be rubber ring jointed.
3. House connection pipes up to 150mm dia may be PVC with solvent joints.
4. Trench width should be equal to the external dia. of the pipe plus a clearance on both sides of the pipe (See table below)

NOM. PIPE DIA. (mm)	MIN. CLEARANCE (mm)
Up to 1800	100
Over 1800	200



SCALE: N.T.S.

DATE: Dec 2012

APPROVED:

DRAWN: S.R. / P.J.D

CHECKED: DS


INFRASTRUCTURE MANAGER

LAST AMENDED:
June 2013

PIPE LAYING DETAIL

SD 100
PAGE 1 OF 1